



**IMPORTANT**  
 Pn = Greater of the single phase measurement  
 Between : phase to Neutral  
 Zb = Earth fault loop impedance at the  
 distribution board (or switchgear)  
 NB  
 Unable to disconnect main equipotential  
 bonding conductors Ze becomes Zdb

TRANSFORMER No. 1

Manufacturer	ENGLISH ELECTRIC
Year	1965
Serial Number	L1155126821
Size kVA	500
Volts H.V.	11000
Volts L.V.	433-250
Amps H.V.	26.25
Amps L.V.	66.7
Impedance Volts %	4.75
VECTOR SYMBOL	Dyn11
Cooling	ON
OIL CAPACITY	168 GALLONS

1	03-12-2008	C.M. & W.S.
REV/ISSUE	DATE	INSPECTORS
<b>ABC</b> ABC BAKERIES		
PROJECT TITLE		
NETWORK SCHEMATIC		
DRAWING No:	T-10-01	
JOB No:	MA-708	
ABC PRODUCTS EASTWOOD ROAD DARTFORD KEN DA1 4PT		
NAME:	DATE:	
DRAWN BY:	J. SMITH	03-12-2008
CHECKED BY:	S.M.C.	03-12-2008

